



People. Partnership. Performance.

P.O. Box 1837  
Tacoma, WA 98401-1837  
www.portoftacoma.com

April 19, 2016

**TO: PLANHOLDERS**

**SUBJECT: PIER 4 PHASE 2 RECONFIGURATION**  
PROJECT NO. 091251  
CONTRACT NO. 070136

**ADDENDUM NUMBER ONE**

This addendum is issued to amend the following:

**SPECIFICATIONS**

**A. 00 11 13 – ADVERTISEMENT FOR BIDS**

1. **ADD** to Pre-bid Conference and Site Tour the following:

A second site visit has been set for May 6, 2016 at 11:30 AM. The site visit will convene at the Contractor Laydown Area denoted on Drawing G5.1 Overall Site Plan. Attendees should bring identification and a high visibility vest/jacket.

**B. 01 14 00 – WORK RESTRICTIONS**

1. **ADD** paragraph 1.04.A.5:

5. Contractor is to note within the Water Quality Certification #NWS-2014-0456-WRD, dated November 6, 2015 and Amendment dated March 2, 2016, located in Appendix G, under paragraph B.2 - Water Quality Monitoring, there is reference to the Pier 4 Reconfiguration Project Water Quality Monitoring and Protection Plan (WQMPP) dated August 24, 2015. The WQMPP has been revised and accepted by the Department of Ecology. The Contractor is to adhere to the requirements of the WQMPP dated March 29, 2016 located in Appendix C in lieu of the August 24, 2015 plan.

**C. 28 31 00.01 FIRE ALARM SYSTEM**

1. **REVISE** paragraph 2.01.A to read as follows:

A. The fire alarm system design is based on equipment as manufactured by Silent Knight Farenhyt 1FP-1000 or Gamewell-FCI E3 Series and accompanying components. Any changes resulting from differences between the specified product and substitute manufacturers shall be the responsibility of the contractor as specified under the Division 01 requirements.

**DRAWINGS**

**A. DRAWING C6.3 UTILITY PLAN – SHEET 3**

1. **DELETE** 10-inch diameter gate valve located at Station 21+14.53.

**Receipt for this addendum shall be indicated in the space provided in Section 00 41 00, Bid Form.**

**END OF SECTION**